

Pure Rain Chemical Testing Data



Sample Number: 08100382-02 Site: Pure Rain Customer Sample ID:

Parameter	Result	Units	Acceptable Level	Pass/Fail	Analysis date	Analyst
E. coli	Absent	P/A	0	Pass	10/14/2008 12:30:00 PM	SRS
Total Coliform	Absent	P/A	0	Pass	10/14/2008 12:30:00 PM	SRS
Nitrate as N	<1.0	mg/L	10	Pass	10/14/2008 8:08:00 PM	RCS2
pH, Lab	6.17	ph Units		Fail	10/15/2008 12:00:00 PM	CH
Nitrite as N	<0.1	mg/L	1	Pass	10/14/2008 8:08:00 PM	RCS2
Fluoride	<0.2	mg/L	4	Pass	10/14/2008 8:08:00 PM	RCS2
Chloride	<10	mg/L	250	Pass	10/14/2008 8:08:00 PM	RCS2
Sulfate	<10	mg/L	250	Pass	10/14/2008 8:08:00 PM	RCS2
Hardness, Total as CaCO3	<10	mg/L	N/A		10/16/2008 10:50:00 AM	CH
Arsenic	<0.003	mg/L	0.01	Pass	10/15/2008 8:42:00 AM	SMR
Iron (Total)	<0.05	mg/L	0.3	Pass	10/15/2008 3:38:00 PM	SMR
Manganese	<0.01	mg/L	0.05	Pass	10/15/2008 3:38:00 PM	SMR
Lead (Standing)	<0.003	mg/L	0.015	Pass	10/15/2008 8:42:00 AM	SMR
Lead (Flushed)	<0.003	mg/L	0.015	Pass	10/15/2008 8:42:00 AM	SMR
Copper (Standing)	<0.05	mg/L	1.3	Pass	10/15/2008 1:48:00 PM	SMR
Copper (Flushed)	<0.05	mg/L	1.3	Pass	10/15/2008 1:48:00 PM	SMR
Benzene	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
Sample pH > 2 at time of analysis						
Carbon Tetrachloride	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
1,2-Dichloroethane	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
1,2-Dichlorobenzene	<0.5	ppb	600	Pass	10/14/2008 4:32:00 PM	RCS2
1,4-Dichlorobenzene	<0.5	ppb	75	Pass	10/14/2008 4:32:00 PM	RCS2
1,1-Dichloroethene	<0.5	ppb	7	Pass	10/14/2008 4:32:00 PM	RCS2
cis-1,2-Dichloroethene	<0.5	ppb	70	Pass	10/14/2008 4:32:00 PM	RCS2
trans-1,2-Dichloroethene	<0.5	ppb	100	Pass	10/14/2008 4:32:00 PM	RCS2
Dichloromethane (Methylene Chloride)	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
1,2-Dichloropropane	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
Ethyl Benzene	<0.5	ppb	700	Pass	10/14/2008 4:32:00 PM	RCS2
Styrene	<0.5	ppb	100	Pass	10/14/2008 4:32:00 PM	RCS2
Tetrachloroethene	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
Toluene	<0.5	ppb	1000	Pass	10/14/2008 4:32:00 PM	RCS2
1,2,4-Trichlorobenzene	<0.5	ppb	70	Pass	10/14/2008 4:32:00 PM	RCS2

Sample Number: 08100382-02 Site: Pure Rain Customer Sample ID:

Parameter	Result	Units	Acceptable Level	Pass/Fail	Analysis date	Analyst
1,1,1-Trichloroethane	<0.5	ppb	200	Pass	10/14/2008 4:32:00 PM	RCS2
1,1,2-Trichloroethane	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
Trichloroethene	<0.5	ppb	5	Pass	10/14/2008 4:32:00 PM	RCS2
Vinyl Chloride	<0.5	ppb	2	Pass	10/14/2008 4:32:00 PM	RCS2
Chlorobenzene	<0.5	ppb	100	Pass	10/14/2008 4:32:00 PM	RCS2
Total Xylenes	<0.5	ppb	10000	Pass	10/14/2008 4:32:00 PM	RCS2
35 Unregulated VOCs	None detected	ppb		N/A	10/14/2008 4:32:00 PM	RCS2
Methyl-t-butyl ether (MTBE)	<0.5	ppb		N/A	10/14/2008 4:32:00 PM	RCS2
Total Trihalomethanes	<0.5	ppb	80	Pass	10/14/2008 4:32:00 PM	RCS2

Comments:

